

# Ohio Department of Transportation Prebid Questions

Project No. 060323

Sale Date - 7/12/2006

---

Question Submitted: 7/10/2006

Question Number: 1

What is the purpose of bid item 20 (1 1/2" duct cable with two no. 4 AWG 5000 volt cables?) Also, where is it to be installed?

**This item is to be used to replace and relocate the ODOT Electric line located at the inlet of the culvert under "Ramp E". Refer to sheet 7.**

---

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.