

Ohio Department of Transportation - Prebid Questions

Project No. 128001

Sale Date - 2/23/2012

ATB-81569 - US-6/85-21.90/0.00,PART1;ATB-85-0.49,PART 2

Question Submitted: 2/16/2012 9:56:38 AM

This question covers Ref# 131 for "High Early strength KEYWAY Grout" for keyways. The APPROVED PRODUCTS LIST (DATED 11-01-10) states: Use material code 42702 for high early strength keyway grout. Products are identified on this list with an (*) and should only be used when required by Standard Drawing PSBD-1-93 Alternate 2. (There are no products at this time)."

With no products approved, what shall be used to grout these keyways???

: If the grout specified to be used by "Alternate 1" or "Alternate 2" (on Standard Drawing PSBD-2-07) is not available then Contractor may use grout that conforms to CMS 705.22 or the Proposal Note for High Early Strength Keyway Grout.

Question Submitted: 2/15/2012 2:55:17 PM

Please provide the list of DBE contractors that the Department considered for establishing the DBE Goal on this project and which work types they might perform. This project is located in an area with very few DBE Contractors, has limited Work Types, and has a relatively low contract value associated with those work types to be subcontracted. Also would the Department consider lowering the DBE goal due to the limited availability of subcontractor work on this project?

Question Submitted: 2/14/2012 11:26:11 AM

Knowing that the Tied Concrete Mats currently on the QPL list are being reviewed I would like to know whether all on the Type 2 mats listed would be able to be used on this project since this is being installed in a creek bed?

Yes, the materials shown in the plans you have the question concerning will be used for the project.