

Ohio Department of Transportation - Prebid Questions

Project No. 120238

Sale Date - 4/26/2012

ATB-81585 - US-6/45/166-2.63/0.00/0.00#1;ATB-166-1.46#2;ATB-6-5.62#3

Question Submitted: 4/20/2012 9:57:12 AM

Ref# 220 The quantity of drip strip can't be right. I think the # for sy of waterproofibf got slipped in.

Question Submitted: 4/17/2012 11:52:41 AM

Take another look at the quantity for drip strip for REF # 220. the plan quantity of 538 feet is way too much. The bridge is only 134 foot long.

Question Submitted: 4/9/2012 2:40:28 PM

This question covers Ref# 213 for "High Early strength Keyway Grout" for keyways. The APPROVED PRODUCTS LIST (DATED 02-21-12) states: "Use material code 42702 for high early strength keyway grout. Products are identified on this list with an (*) and can only be used when specified by Standard Drawing PSBD-1-93 Alternate 2. (Currently, there are no products on the list)."

With no products approved, what shall be used to grout these keyways???

If the grout specified to be used by "Alternate 1" or "Alternate 2" (on Standard Drawing PSBD-2-07) is not available then Contractor may use grout that conforms to CMS 705.22 or the Proposal Note for High Early Strength Keyway Grout.

Question Submitted: 3/28/2012 9:35:07 AM

This question covers Ref# 213 for "High Early strength Keyway Grout" for keyways. The APPROVED PRODUCTS LIST (DATED 11-01-10) states: Use material code 42702 for high early strength keyway grout. Products are identified on this list with an (*) and should only be used when required by Standard Drawing PSBD-1-93 Alternate 2. (There are no products at this time)."

With no products approved, what shall be used to grout these keyways???

If the grout specified to be used by "Alternate 1" or "Alternate 2" (on Standard Drawing PSBD-2-07) is not available then Contractor may use grout that conforms to CMS 705.22 or the Proposal Note for High Early Strength Keyway Grout.