

Ohio Department of Transportation - Prebid Questions

Project No. 120657

Sale Date - 12/13/2012

ATB-82932 - SR-193-22.54, PART 1;ATB-193-23.16, PART 2

Question Submitted: 12/7/2012 10:18:03 AM

There is no item for pavement removal on part 2 for the box culvert. Is it intended to be part of excavation or incidental to the proposed culvert? Please clarify or issue pay item. Thank you.

The 28 CY of Excavation shown on sheet P2-14 between Cross Section 32+55.00 & Cross Section 32+75.00 is for the removal of the existing pavement.

Question Submitted: 11/20/2012 2:54:23 PM

Can you provide a set of drawings for the existing arch bridge structure on ATB-193-22.54?
Thank-you

<ftp://ftp.dot.state.oh.us/pub/Contracts/Attach/ATB-82932>