

Ohio Department of Transportation Prebid Questions

Project No. 080650

Sale Date - 12/10/2008

Question Submitted: 3/17/2009

Question Number: 1

Item 631, Misc: Removal of Foundation plan note (Ppg. 2) notes the removal and disposal of two (2) foundations. Shall these foundations be removed entirely (full depth), or removed 1 ft. minimum below grade per CMS 632.26?

The foundations are to be removed to a minimum of 1 foot below grade.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.