

Ohio Department of Transportation - Prebid Questions

Project No. 130149

Sale Date - 3/14/2013

ATB-84607 - US-6/534-1.54/(7.77)(22.22)

Question Submitted: 2/19/2013 3:44:24 PM

This question covers Ref# 43 and Ref# 62 for "High Early strength Keyway Grout" for keyways. The APPROVED PRODUCTS LIST (DATED 02-21-12) states: "Use material code 42702 for high early strength keyway grout. Products are identified on this list with an (*) and can only be used when specified by Standard Drawing PSBD-1-93 Alternate 2. (Currently, there are no products on the list)."

With no products approved, what shall be used to grout these keyways???

If the grout specified to be used by Alternate 1 or Alternate 2 (on Standard Drawing PSBD-2-07) is not available then the Contractor may use grout that conforms to CMS 705.22 or the Proposal Note for High Early Strength Keyway Grout.