

# Ohio Department of Transportation - Prebid Questions

Project No. 130060

Sale Date - 1/31/2013

ATB-85231 - SR-193-11.33

*Question Submitted:* 1/28/2013 11:54:53 AM

Plan sheet 5/36 Items 451 & 452, as per plan note indicates the safety edge is required and incidental to these concrete items. Is the safety edge also required and incidental to the Item 526 Reinforced Concrete Approach Slabs, as well as the 8" non-reinforced concrete pavement items?

*Question Submitted:* 1/28/2013 11:52:17 AM

Plan sheet 8/36 Designated Local Detour Route. What materials, quantities, and method of payment are to be used for maintenance of the local detour?

*Question Submitted:* 1/15/2013 9:06:46 AM

This question covers Ref# 64 for "High Early strength Keyway Grout" for keyways. The APPROVED PRODUCTS LIST (DATED 02-21-12) states: "Use material code 42702 for high early strength keyway grout. Products are identified on this list with an (\*) and can only be used when specified by Standard Drawing PSBD-1-93 Alternate 2. (Currently, there are no products on the list)."

With no products approved, what shall be used to grout these keyways???

**If the grout specified to be used by Alternate 1 or Alternate 2 (on Standard Drawing PSBD-2-07) is not available then Contractor may use grout that conforms to CMS 705.22 or the Proposal Note for High Early Strength Keyway Grout.**