

Ohio Department of Transportation - Prebid Questions

Project No. 103017

Sale Date - 10/21/2010

ATB-86995 - SR-45/90-19.89/(2.33)(7.43)

Question Submitted: 10/8/2010 2:19:14 PM

Can the existing bridge drawings be posted to the District ftp site

The information requested can be obtain from the Office of Contracts. This information is provided on a CD/DVD for Design Build Projects and is provided with the bidding package from the Office of Contracts.

Question Submitted: 10/5/2010 10:13:54 AM

The MOT restriction indicated in 13.3 for structure ATB-90-0743 is a 5 day detour duration. 13.3 also indicates "all" work on this structure will be completed during the detour. This is not possible. The wet cure period alone per SS848 for a micro-silica overlay is 3 days. With the amount of work indicate in 15.4 the detour duration needs to be adjusted to 30 days.

See forthcoming addendum

Question Submitted: 10/5/2010 10:09:11 AM

1. A DBE Goal of 11% is excessive, please consider reducing this goal.

The goal will remain at 11%. If the awarded contractor is unable to meet the assigned goal, the process to request a partial waiver of the goal is described in Proposal Note 22.