

Ohio Department of Transportation - Prebid Questions

Project No. 120436

Sale Date - 6/21/2012

ATB-90596 - VA-SP-FY2013(EAST)

Question Submitted: 6/15/2012 3:45:26 PM

The partial depth item is specified to be paved with a type 1 @3" depth, can this material be placed in one lift?

No, it cannot. Place the partial depth item in two (2) 1.5"-thick lifts.