

Ohio Department of Transportation Prebid Questions

Project No. 062000

Sale Date - 1/11/2006

Question Submitted:

Question Number: 1

1) Can't find the voltage for pump station at Gallia and Albany. 2) Is the fencing at Albany to remain to be removed? 3) Is compaction to be by the spec book? What section? 4) Addendum 2, prebid question 4, are you sure the answer for backfill given is what you want for Tupper Plains? 5) Need a paper bidding document to submit written bid.

1) Pumps are specified in the bidding documents. Voltage shall be as specified by pump supplier. 2) Remain. 3) Yes CMS 603.10 D 4) Yes 5) Written bids are not acceptable, please see addendum 1.

Question Submitted: 1/5/2006

Question Number: 2

The pipe for the 2 force mains is called out on sheet 2/34 to be AWWA C900. The plans call out for the Albany site to have a 3" force main and the Tupper Plains site to have a 2" force main. AWWA C900 pipe is not made in a 2" or 3" size. The smallest size for C900 pipe is 4".

What type of pipe should be used for the force mains calling for 2" and 3"?

Please see addendum #2.

Question Submitted: 1/6/2006

Question Number: 3

The lift station and valve vault for the Albany site is shown on sheet 8. The details show the type and location of the control panel for the lift station. There are no details on the control panel showing operation. Can this be obtained?

The pump manufacturer is specified in the bidding documents. Control panel designed and built by supplier.

Question Submitted: 1/6/2006

Question Number: 4

plan sheet 8/34
pump station design data no voltage shown

also section a-a nema 3R control panel need to know specification

is their a bid item for electrical work

1) The pumps have been specified in the bidding documents. Voltage shall be per manufacturer's specs. 2) Control panel will be as designed and built by the supplier.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.