

Ohio Department of Transportation - Prebid Questions

Project No. 140126

Sale Date - 3/13/2014

ATH-91461 - SR 13 0.080

Question Submitted: 3/7/2014 2:58:29 PM

Line item #9 is 11 sf. Plans show 11 ea or 88 sf.

Error is addressed in forthcoming Addendum 1.

Question Submitted: 3/7/2014 9:32:53 AM

Reference 20 of the Proposal and the General Summary on Sht 9 is a 448 Asphalt Type 1. The Sub-Summary on Sht 10 specifies a 448 Type 2 for this Item. Please clarify which material is required.

The bid item will be revised to Type 2 Intermediate PG 64-22 in a forthcoming Addendum.

Question Submitted: 3/6/2014 10:17:58 AM

Line 20 of the Proposal is 8075 cy of Asphalt Intermediate Type 1, PG64-22. This Item appears on the General Summary as a Type 1 on Sheet 9. The Subsummary on Sheet 10 specifies 1.75" of Type 2 PG64-22. Please clarify which material is to be used for this Item.

The bid item will be revised to Type 2 Intermediate PG 64-22 in a forthcoming Addendum.

Question Submitted: 2/26/2014 11:47:16 AM

Regarding Items 644-

Can 647- Type B90 or Type B125 Material be used in place of 644- items?

No. Material used shall be as per plan.