

Ohio Department of Transportation - Prebid Questions

Project No. 160562

Sale Date - 11/3/2016

ATH-91781 - SR 681-07.79

Question Submitted: 10/28/2016 9:56:40 AM

Plan Sheet 6 of 7; Is it ODOT's intent to pay the Contractor the calculated SY's for the Double Chip Seal for just one application (or the second application) after the Single Seal has been applied to entire road? If not the Single Chip Seal quantity is overstated, please advise.

The intent is to pay the calculated SY for double chip seal as a single (second) application in the specified locations. The single chip seal quantity will pay for one application over the entire segment.

Question Submitted: 10/28/2016 9:42:29 AM

What type of pavement marking material was used on the existing roadway and will it be required to be removed?

The existing long line pavement markings are Item 642 – Traffic Paint and do not require removal. The auxiliary markings are Item 644 – Thermoplastic paint. All Thermoplastic paint shall be removed.