

Ohio Department of Transportation - Prebid Questions

Project No. 138041

Sale Date - 8/29/2013

ATH-92321 - SR-682-2.14

Question Submitted: 8/28/2013 3:37:27 PM

Is the existing reinforcement remaining in the approach slabs? There is no epoxy coated reinforcing steel for this listed.

The existing reinforcing does not remain. All of the approach slabs are to be removed. The steel list is in the standard drawing and the cost is included with the approach slab pay item.