

Ohio Department of Transportation - Prebid Questions

Project No. 168032

Sale Date - 8/25/2016

ATH-97323 - Culvert Replacement FY2016

Question Submitted: 8/22/2016 12:10:04 PM

On pages 41 & 42, the headwalls designs refer to Standard Drawings HW-1.1. However the Standard Drawings refer to circular pipe and not elliptical. Can you please clarify which specific headwall size to use and if there are going to be modifications in dimensions to accommodate the elliptical pipes?

Set the wing wall lengths and middle section based on the span of the elliptical closest to the round pipe size and the height to the closest round pipe size. The note that allows this standard to be used for elliptical and arches, and how to use it, is shown on the standard drawing.