

Ohio Department of Transportation Prebid Questions

Project No. 078001

Sale Date - 4/27/2007

Question Submitted: 4/13/2007

Question Number: 1

Please make the Proposal available on your website.

Now available

Question Submitted: 4/23/2007

Question Number: 2

Can the existing drawings for structures AUG-501-5.08 and AUG-501-5.34 be made available on line?

<ftp://ftp.dot.state.oh.us/Pub/Contracts/Plans/078001/>

Question Submitted: 4/26/2007

Question Number: 3

Please disregard previous question. Culvert that was eliminated by addendum no. 1 had no guardrail. Thanks.

Question Submitted: 4/26/2007

Question Number: 4

The guardrail quantities for Structure AUG-66-17.30 are still included in the project and were not changed by addendum no. 1. Will this work be performed? Under traffic? The removal of this guardrail was pulled out by addendum no. 1 I think the guardrail items should have been revised.

The guardrail qty which are still in the project are for AUG-501 not AUG-66. There was no proposed guardrail on the AUG-66 structure.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.

Ohio Department of Transportation Prebid Questions

Project No. 070111

Sale Date - 3/16/2007

Question Submitted: 2/13/2007

Question Number: 1

Plan page 53/65 states that "deck concrete shall be placed monolithically with the pier caps and approach slabs". We request that a construction joint be considered between the pier cap and the deck.

A Construction Joint is shown in Standard Construction Drawing "CPP-2-94", dated "07/19/02".

Question Submitted: 2/8/2007

Question Number: 2

We request that a construction joint be considered between the pier cap and the poured deck on bridges 501-5.08/5.34.

A Construction Joint is shown in Standard Construction Drawing "CPP-2-94", dated "07/19/02".

Question Submitted: 3/5/2007

Question Number: 3

Calendar days and completion date. There are 3 structures on this project - 2 that have 130 calendar days to complete and the other one has 15. The 2 with 130 days can not be done at the same time. With 260 work days, the completion date can not be 8-31-07. Please confirm.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.