

Ohio Department of Transportation Prebid Questions

Project No. 090221

Sale Date - 4/15/2009

Question Submitted: 11/20/2008

Question Number: 1

1. Can existing bridge plans be made available to bidders?2. What is the normal water elevation?

Ans: 1. Existing plans are available at: <ftp://ftp.dot.state.oh.us/pub/Contracts/Attach/AUG-82706/ANS> : 2. This structure solely allows passage of flood flows from the Saint Marys River and thus has no ordinary high water level.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.