

# Ohio Department of Transportation - Prebid Questions

Project No. 130037

Sale Date - 1/17/2013

AUG-87733 - VA-MICRO-PM-FY2013

Question Submitted: 1/14/2013 4:29:05 PM

Can the depressions caused by removing the existing RPM's be filled individually prior to the leveling course of microsurfacing with microsurfacing material? This method has been used successfully on other ODOT microsurfacing projects.

**Yes, microsurfacing material may be used to fill the depressions left from RPM removal provided they are filled ahead of the microsurfacing operation.**