

Ohio Department of Transportation - Prebid Questions

Project No. 150250

Sale Date - 5/7/2015

AUG-88800 - SR 219-7.21

Question Submitted: 4/30/2015 10:31:05 AM

Are the existing bridge plans available to be loaded onto ODOT's ftp site?

Yes, they will be posted to: <ftp://ftp.dot.state.oh.us/pub/Contracts/Attach/AUG-88800/Reference%20Files/>

Question Submitted: 4/27/2015 11:52:52 AM

For Line No. 53 - Steel Points or Shoes, does ODOT want conical points or end plates for the 12" and 16" diameter cast-in-place reinforced concrete piles?

Use conical points.

Question Submitted: 4/26/2015 9:23:29 PM

Will ODOT consider extending the completion date to Oct. 31st on this project?

No. Completion date of 9/30/15 remains.

Question Submitted: 4/16/2015 6:07:46 AM

Can an optional construction joint be added to the abutment at the approach slab seat elevation?

Please bid as per plan.