

Ohio Department of Transportation - Prebid Questions

Project No. 160074

Sale Date - 2/11/2016

AUG-93855 - US 33/SR 116-4.19/1.31

Question Submitted: 1/27/2016 4:34:49 PM

Does the Department want the 12 each, Scupper Modification bars galvanized?

Yes. Per CM&S 518 scuppers shall be galvanized.

Question Submitted: 1/25/2016 9:47:52 AM

Sheet 10 shows 2" of Micro-silica overlay being removed from the approach slabs and replaced with item 442 asphalt concrete surface course, 12.5mm type a (448) while the surround area is being replaced with Item 441 asphalt concrete, type 1, (448) PG-64-22 I have 2 questions First: why the Two Different mixes for such a small quantity and second can we use just use Item 441 asphalt concrete surface course, type 1, (448), Pg64-22 over the entire area and approach slab? This small amount of item 442 asphalt concrete surface course, 12.5mm type A, (448) may delay the paving since it is not always readily available at the asphalt plants.

Reference to 441 on sheet 10 is incorrect. 442 is required over both approach slab and surrounding pavement. 441 will not be allowed at this structure. An addendum will be processed to remove the incorrect reference to 441 on sheet 10.