

Ohio Department of Transportation - Prebid Questions

Project No. 164008

Sale Date - 10/20/2016

AUG-94787 - US 33-20.87

Question Submitted: 9/19/2016 1:01:06 PM

This project is announced as a sliplining project. Will you consider a spin cast geopolymer liner in place of sliplining?

No. spin cast geopolymer liner will not be allowed.

Question Submitted: 9/15/2016 3:03:37 PM

The project calls for 'sliplining'; we are a shotcrete contractor that can line CMP's, RCP's, & brick Sewers full circumference and currently have an ODOT maintenance contract. Would Shotcrete be allowed as an alternate to the sliplining?

No. Shotcrete will not be allowed.