

# Ohio Department of Transportation - Prebid Questions

Project No. 140461

Sale Date - 9/4/2014

AUG-97172 - IR 75-5.45

*Question Submitted:* 8/27/2014 1:04:28 PM

Can you clarify if the new stiffener will be installed in the damaged part of the main member?

**Yes.**

*Question Submitted:* 8/27/2014 8:32:19 AM

Is it the intent of the department to put new stiffeners and cross frames in without straightening the bent main members?

**That is correct.**