

# Ohio Department of Transportation - Prebid Questions

Project No. 177000

Sale Date - 2/2/2017

BEL-101412 - IR 70-23.69

*Question Submitted:* 1/30/2017 1:09:06 PM

Item 305 9" Concrete Base. Would the department waive specification 451.04 and allow hand placement?

*Question Submitted:* 1/30/2017 11:18:24 AM

Line Item 0017 9" Concrete base has a pay quantity of 48 SY. Please clarify whether the unit is supposed to be by SY or CY.

**The quantity for ITEM 305E13010 – 9" Concrete Base, Class QC1 should be calculated in units of SY. The correct quantity is 189 SY. This change is anticipated to be made in Addendum #2.**

*Question Submitted:* 1/9/2017 10:42:10 AM

Please provide soil-boring for this project if available.

**The Geotechnical Exploration sheets referred to on the Title Sheet will be added in Addendum #1.**

*Question Submitted:* 1/9/2017 10:24:52 AM

PLEASE INCLUDE A GEOTECHNICAL REPORT FOR THE SITE, IN AN ADDENDUM.

**The Geotechnical Exploration sheets referred to on the Title Sheet will be added in Addendum #1.**

*Question Submitted:* 1/9/2017 10:00:59 AM

Plan page 6 shows a boring location. Is a boring log available?

**The Geotechnical Exploration sheets referred to on the Title Sheet will be added in Addendum #1.**