

Ohio Department of Transportation Prebid Questions

Project No. 100248

Sale Date - 5/6/2010

Question Submitted: 5/3/2010

Question Number: 1

The completion time for this project seems extremely difficult to achieve with regards to all the repairs beneath the structure that are required. Would the State consider revising completion date to 2011 as long as there is no traffic interference?

The Department will not change the completion date for this project.

Question Submitted: 5/3/2010

Question Number: 2

WOULD THE DEPARTMENT CONSIDER EXTENDING THE PROJECT COMPLETION DATE FOR THE SUBSTRUCTURE REPAIR WORK NOT EFFECTING TRAFFIC, OR ALLOW THE CONTRACTOR TO WORK BEYOND THE COMPLETION DATE WITHOUT LIQUIDATED DAMAGES TO PERFORM WORK ON THE SUBSTRUCTURE THAT DOES NOT EFFECT TRAFFIC. THIS REQUEST IS DUE TO THE LARGE QUANTITIY OF 512 AND 519 REPAIR WORK PROPOSED; DUE TO THE CURE TIMES ASSOCIATED WITH THE CONSTRUCTION OF THESE TWO ITEMS; AND DUE TO THE TEMPERATURES SPECIFIED UNDER THESE TWO RESPECTIVE ITEMS.

The Department will not change the completion date for this project.

Question Submitted: 5/3/2010

Question Number: 3

PLAN NOTE STATES SUPPLIMENTAL SPEC 847 10/16/2009. SHOULD THIS SPEC BE 847 4/16/2010?

No, use the supplemental specification date provided on the title sheet for this project.

Question Submitted: 5/5/2010

Question Number: 4

For the 519 patching concrete repair items the plans call for 3 x 3 - W1.4 x W1.4 epoxy-coated welded wire fabric. After servral days of trying numerous suppliers, they are telling us this material is not available and are quoting alternatives. Can the State provide the source from which this special material was specified for use in these plans?

Question Submitted: 5/5/2010

Question Number: 5

For the 519 patching concrete repair items, the plans call for 3 x 3 - W1.4 x W1.4 epoxy-coated welded wire fabric. After servral days of trying numerous suppliers, they are telling us this material is not available and are quoting alternatives. Can the State provide the source from which this special material was specified for use in these plans?

The 3 x3 welded steel wire fabric using wire size number 1.4 x 1.4 is not typically kept in stock, but can certainly be produced and epoxy coated.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.