

Ohio Department of Transportation - Prebid Questions

Project No. 130087

Sale Date - 2/14/2013

BEL-77355 - IR-70-15.72

Question Submitted: 2/5/2013 11:39:49 AM

Would the department consider changing the mix type to 12.5mm Superpave to match the mix on project 656 which is in the middle of each section of this project?

If not, would the department consider the use of an approved carbonate stone to meet the 100% crush requirements of Item 424 Fine Graded Asphaltic Concrete, Heavy design?

The Department will NOT change the pavement mix type to 12.5mm Superpave. The Department will not accept the use of carbonate stone. This item should be bid as per the plan.

Question Submitted: 2/5/2013 11:37:16 AM

Will the completion date be extended if the traffic scheme on project 120656 Belmont I-70 conflicts with completion on this project?

The completion date will not be extended due to the adjacent work. The Contractor is advised to construct this project in accordance with the "Cooperation Between Contractors" note in the plan.