

Ohio Department of Transportation - Prebid Questions

Project No. 120239

Sale Date - 4/26/2012

BEL-84013 - IR-70-17.52

Question Submitted: 4/19/2012 11:07:33 AM

ITEM 2, CONCRETE BARRIER REMOVED, AS PER PLAN, requires that the barrier top be removed and the footer left in place until it is removed in a later phase. This is so that the footer can be used as temporary pavement. Since the top is dowelled into the footer, it's been our experience that the top and footer cannot be removed separately without going to significant additional expense. Can you give some guidance on how this should be accomplished?

It is the responsibility of the Contractor to determine the "means and methods" of the removal of the top portion of the barrier. As indicated in the plan the Contractor is required to remove the top portion and leave the footer. Any damage to the footer as a result of the removal will need to be repaired at the Contractor's expense.