

Ohio Department of Transportation Prebid Questions

Project No. 090335

Sale Date - 6/24/2009

Question Submitted: 6/17/2009

Question Number: 1

Will the department be performing pavement repairs on HAS 151, COL 45, or BEL 9? If no repairs are performed, is it the intent to seal all visible cracks, which may result in crack sealing material being applied side by side resulting in wide applications of material on pavement?

There is no Pavement Repair quantity provided in the plan, therefore no pavement repairs are anticipated. Apply the crack seal as per the specification.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.