

Ohio Department of Transportation - Prebid Questions

Project No. 160526

Sale Date - 10/6/2016

BEL-91550 - IR 70-12.23

Question Submitted: 10/4/2016 3:16:01 PM

How is the existing Temporary Concrete Barrier Wall removal on the CR78 Bridge to be handled along with drums and signs? If the contractor is to remove these items, please designate where we are to take them.

The temporary MOT items currently in place are the property of ODOT and will be removed by ODOT forces prior to construction. The Contractor will need to coordinate with ODOT on the removal of the items prior to start of construction.

Question Submitted: 9/29/2016 3:29:01 PM

The plan note on sheet 24/67 under Item 503, Cofferdams, Excavation Bracing, As Per Plan states that there is a design shown in the plans for temporary support of excavation. Where is this shown in the plans?

No detail is to be provided. If excavation bracing is required it will be the responsibility of the Contractor to design.

Question Submitted: 9/27/2016 2:22:40 PM

Please provide the plans for the existing bridge. They are not located in the FTP site as per the note on plan sheet 4 of 67.

Please use the following link: <ftp://ftp.dot.state.oh.us/pub/Contracts/Attach/BEL-91550/>

Question Submitted: 9/27/2016 8:30:26 AM

Please provide the plans for the existing bridge. They are not located in the FTP site as per the note on plan sheet 4 of 67.

Please use the following link: <ftp://ftp.dot.state.oh.us/pub/Contracts/Attach/BEL-91550/>