

Ohio Department of Transportation

Prebid Questions

Project No. 080323

Sale Date - 5/21/2008

Question Submitted: 4/15/2008

Question Number: 1

Ref 60 Item 513 Structural Steel. This is a nucor yamato beam because it is A588 and they are the only mill currently rolling A588 steel. The roll date is June 1. the roll cycle for this beam closes on April 28 and it will probably be cast by the time this bids. The next rolling for this beam is October 19, 2008. The completion date for the project is October 31, 2008. May i suggest that the bid be moved into the month of April so this project may be completed on time or the completion date be moved to 2009.

Question Submitted: 5/14/2008

Question Number: 2

Ref 49 642 Center Line, appears to be wrong for quantities in plans.

Reference No. is an estimated contingency quantity only for the portion of the Local Designed Detour that may require restoration after the Construction Project is completed. Payment will be made for actual quantity required to restore the Local Designed Detour after the Construction Project is completed.

Question Submitted: 5/15/2008

Question Number: 3

We are being told that the rolling for the beams is in October 2008. Will you please move the completion date until next year (2009).

Question Submitted: 5/15/2008

Question Number: 4

The description for item number 0070 is "Rock Channel Protection, Type B with Aggregate Filter". Plan sheet 12/31 shows Rock Channel Protection, Type A with Filter Fabric. Which type of rock channel protection is required?

Question Submitted: 5/16/2008

Question Number: 5

Are the abutment diaphragms included for payment with item 0073 "QC/Qa Concrete, Class QSC2, Superstructure (Deck) With Warranty, As Per Plan"?

Yes, the concrete quantities for the abutment diaphragms are in Item 892 QC/QA Concrete, Class QSC2, Superstructure (Deck) With Warranty, As Per Plan.

Question Submitted: 5/7/2008

Question Number: 6

Are SIP forms allowed on this project?

No

Question Submitted: 5/7/2008

Question Number: 7

A plan note on sheet 13/31 refers to detail drawings of the existing bridge. Can these drawings be made available on the department web site?

<http://www.dot.state.oh.us/CONTRACT/FTP/Attach/BRO-75457/>

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.