

# Ohio Department of Transportation

## Prebid Questions

Project No. 090289

Sale Date - 6/3/2009

Question Submitted: 5/27/2009

Question Number: 1

Please verify start date of April 1, 2010 as noted on page 4/25. Since addendum 1 states that the utility work will not be relocated prior to commencing work. Will a new start date be assigned?

**The start date for the project will not be modified, it is correct on sheet 4/25. This start date was selected as a result of allowing time for utility relocation and not starting project in winter months. Addendum 1 states a portion of the utility relocation work will be performed prior to the contractor starting work and a portion to be coordinated with the contractor at the start of the project.**

Question Submitted: 5/29/2009

Question Number: 2

Please confirm in addendum 1 that all box beams must be set from the West side of the bridge do to utility lines not being relocated. If the contractor elects and knows the potential utility issue/hazard, will ODOT allow the contractor to set beams from East side of Bridge at the contractors discretion?

**The project was designed with the anticipation of the beams being set from the West side. The utilities were relocated to allow for work from this side and the maintenance of traffic scheme was arranged to allow for work from this side. If the contractor so chooses he can set the beams from the other side, but the contractor will be responsible for any additional cost to the project. Some additional cost to the project may be but not limited to, additional utility relocation, additional maintenance of traffic work, and no time extension will be granted for the project to allow for beams to be set from this side of the bridge.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.