

Ohio Department of Transportation

Prebid Questions

Project No. 050178

Sale Date - 3/23/2005

Question Submitted: 3/15/2005

Question Number: 1

We install the Special Polymer Modified Asphalt Expansion Joint System in bridges.

There is a total of 3.39 CY of Plug Joint at five locations. Our Contracting Manager physically went to each site and measured each location. There seems to be a great difference of footage, due to the skew not being considered.

The plans show about 292.90 LF and his measurement is about 397 LF. Can you confirm the absolute correct cubic yards?

What about Bridge BUT126-0308 that was skipped? Should this not be included in all this?

Thanks for any help you can offer.

The District has looked into this matter and has included the skew measurements in the calculations. The joints will not exceed into the dirt area at the bridge as shown by the hatched area on sheet 16. Bridge BUT126-0308 did not require Polymer Modified Asphalt Expansion Joints.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.