

Ohio Department of Transportation

Prebid Questions

Project No. 101067

Sale Date - 4/15/2010

Question Submitted: 3/17/2010

Question Number: 1

Ref: 0028,0076, 0077. What galvanizing procedure is to be used. Are these items to be removed and shipped to galvanizing plant, or are the items to be touched up in the field. If they are to be touched up in the field, what galvanizing method is to be used. CMS 711.02 states no galvanizing spray, is there a galvanizing paint that is acceptable to ODOT, if so what is it.

See the addendum.

Question Submitted: 4/9/2010

Question Number: 2

Bid reference # 67 requires a TC-81.21 design 4 pole per the proposal description. However, the pole chart on plan pages 42 & 43 show this pole upright as a design 3. Like wise, bid reference # 69 is shown in the proposal as a design 2 pole and arm, but is listed as a design 1 in the same pole chart. Please clarify if the proposal descriptions are correct or if an addendum will be issued to match these items with the pole chart.

Bid the reference items as shown in the Proposal. The information about these signal designs on plan sheets 42 and 43 is incorrect. The Federal Color Number for the painting required on this project should be Gloss Black, closely agreeing with Federal Standard 595, Color 17038.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.