

# Ohio Department of Transportation

## Prebid Questions

Project No. 070139

Sale Date - 3/16/2007

Question Submitted: 3/9/2007

Question Number: 1

As part of the project, the contractor is required to install 460 lf of 8" sanitary. If review of the plan & profile sheets, (page 19 & 20) it appears the new sanitary runs parallel to overhead electric power lines that are in close proximity to the new sanitary. The proposal notes do not indicate the lines will be removed. Given the depth of sanitary lines ( 7 to 12') and the size equipment required to excavate at this depth, if a contractor believes it is unsafe to operate equipment this close to the power lines and poles, will the power lines or possibly the sanitary line be relocated?

**The contractor will have to work around the utility. The proposed sanitary line will not be relocated.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.