

# Ohio Department of Transportation Prebid Questions

Project No. 080452

Sale Date - 7/9/2008

Question Submitted: 6/19/2008

Question Number: 1

Please specify which polymerized emulsions can be used for the 422 - Single Chip Seal. Can we use either HFRS-2 or CRS-2P?

**Refer to sheet 15/18. Plan note Item 422 - Single Chip Seal, As Per Plan states "A Polymer Emulsified Binder conforming to 702.16, Type A shall be used."**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.