

# Ohio Department of Transportation

## Prebid Questions

Project No. 060068

Sale Date - 2/1/2006

Question Submitted: 1/24/2006

Question Number: 1

Reference #49 - at station 26+50 and at station 24+50 the soil boring are not as deep as the prebored holes as per plan. If the rock is not drillable, how will this issue be addressed and paid for?

**Based on the soil borings provided, the district anticipates the rock to be drillable throughout the project limits. The Contractor should base his bid according to the provided soil borings and plan sheets. Changed conditions are subject to compensation.**

Question Submitted: 1/24/2006

Question Number: 2

Reference #46 thru #54 (work type 34) and combined with the paving items are highly specialized items. I feel it would be hard to maintain 50% of the items. Could the 50% rule be altered?

**The Department respectfully declines to change the percentage.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.