

Ohio Department of Transportation - Prebid Questions

Project No. 120123

Sale Date - 3/8/2012

COL-84005 - SR-7-0.58

Question Submitted: 3/3/2012 11:16:14 AM

Bid reference # 44 is listed in the proposal as Design A20830, which is not a conventional design configuration. The plans show this pay item should be design A20B30. Will an addendum be issued to correct this pay item?

Question Submitted: 3/1/2012 2:26:30 PM

Regarding Ref. 109 Removal of Existing Coatings from Concrete Surfaces, the plans are showing the removal to be on the piers. There is one tall mse/abutment wall on this bridge that has existing sealer, as well as the wing walls, will the removal of this existing sealer be covered under Ref. 109?

The quantity provided in the plan does not include the removal of the material on the abutment or wingwalls. An addendum will be required.