

## Ohio Department of Transportation - Prebid Questions

Project No. 120583

Sale Date - 10/18/2012

COL-84363 - SR-7-11.98

Question Submitted: 10/9/2012 12:56:27 PM

Plan notes on pg. 10 indicate that 302 Asphalt base is to be used in the partial depth repair item. Can the contractor elect to use 301 asphalt base in lieu of the 302 for the partial depth repairs?

**No**