

Ohio Department of Transportation - Prebid Questions

Project No. 133021

Sale Date - 11/7/2013

COL-94449 - SR-11-17.70

Question Submitted: 11/6/2013 10:08:52 AM

Several prebid question were recently posted for this design build project. These questions are relevant to estimating this project. This information is not in the current scope of service and needs to be clarified and issued prior to the bid in an addendum.

Bid accordingly and as per the Prebid Question Answer clarifications. No further addenda will be issued.

Question Submitted: 11/5/2013 3:44:23 PM

Scope of Services section 16.1 A. specifies 642 paint pavement markings. However, proposal bid item reference number 14 specifies 646 epoxy pavement markings. Which is the intended material?

Bid the reference item, 646E99000, Epoxy Pavement Marking, as the intended material.

Question Submitted: 11/5/2013 1:27:53 PM

Scope of Services 15.4 requires the conversion of the wingwalls to straight walls, adding piling, footings, and walls. The requirements are to drive the same piling section and to the depth as in the original plan. Are we to assume that a Dynamic Pile test is not required?

Dynamic Load Testing is not required.

Question Submitted: 11/4/2013 9:38:47 PM

The Scope of Services does not require or give the limits of any Sealing of Concrete, yet there is a line item for such in the proposal form under both structures. Is sealing required? If so, what are the limits?

Refer to Section 15.4 for the concrete sealer requirements.

Question Submitted: 9/29/2013 2:29:58 PM

Please post the pre bid meeting minutes and reply to the previous question asked several weeks ago.☹

As soon as the Pre-Bid Meeting Minutes are available from the stenographer, they will be posted. The question that was asked by the bidder prior to the Pre-Bid Meeting was discussed at the Pre-Bid Meeting and will be in the Minutes.

Question Submitted: 9/12/2013 9:40:57 AM

THE SCOPE STATES THE PROJECT LIMITS ARE FROM SLM 17.2 TO SLM 18.2, IS THE INTENT TO REMOVE ALL THE PAVEMENT FOR 1 MILE? IT WILL BE HELPFULL TO KNOW JUST WHAT THE PAVING LIMITS ARE. ALSO PAVEMENT BUILDUP IS GIVEN FOR SR-517, IS PAVEMENT REQUIRED THERE ALSO. IF SO WHAT ARE THE LIMITS. LASTLY, THE PREBID MEETING SCHEDULED FOR SEPT. 26 AT 10:00 IS A LETTING DAY.

These questions can be asked and answered at the prebid meeting. The prebid meeting date will remain as scheduled.