

Ohio Department of Transportation

Prebid Questions

Project No. 060245

Sale Date - 5/17/2006

Question Submitted: 5/12/2006

Question Number: 1

Please clarify the note on page 6 of 15 - Placing/Planing of Asphalt Concrete. The first sentence appears to say full width and the second sentence appears to say half width along the center lane is allowed.

The intent of the notes are to prohibit drop-offs regardless of direction.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.