

Ohio Department of Transportation - Prebid Questions

Project No. 100464

Sale Date - 8/12/2010

CUY-82794 - VA-LAKEWOOD SIGNALS-PHASE 2

Question Submitted: 8/9/2010 3:11:19 PM

On intersection corners where plan work has to be performed that is virtually impossible to do that work and not remove more sidewalk/curb ramps than the plan quantity at that location calls for, how are we to be compensated for this work?

The plan quantities have been reviewed and it is the Districts opinion the plan quantities are adequate to perform the necessary work. Please bid as per plan.

Question Submitted: 8/9/2010 10:26:22 AM

Signal Supports and pedestals (bid reference # 54 through #71) are either As Per Plan type A or As Per Plan Type B. However these items are not set up as alternates in the proposal? It appears that only one or the other type will be provided. Will these items be evaluated as alternates or are both going to be needed?

The pay items are set up this way due to 3 funding sources on the project. As Per Plan Type A is for the generic pole and Type B is for the decorative pole. The Earmark funding shown in the general summary will pay for the difference between Type A and Type B, the federal funds will pay for the generic pole. The intent is to provide decorative poles with federal funds paying the base cost and the earmark funds to make up the difference for the decorative poles.

Question Submitted: 8/4/2010 9:00:14 AM

Pedestal 8'Transformer base as per plan A- this says that these are to be painted and primed as described in item 632- signal support, however, this specification does not reference painting or priming.

The plan note reads "In addition to the requirements of Item 632 and 732, pedestals and bases shall be painted and primed as described in Item 632 - Signal Support, Type TC-81.21, as per plan A", which is referring to the plan note directly above the plan note in question. That note describes in detail what is required for the priming and painting.

Question Submitted: 8/3/2010 3:54:36 PM

There are no dimensions for all of the signs that will require items #0022 and #0023 "sign hanger assembly" so we cannot determine which sign hanger assembly to bid- we need to know the sizes of the signs.

The sign dimensions are located on sheets 43G/44 through 43I/44.

Project No. 100466

Sale Date - 8/12/2010

DEL-86774 - VA-OLENTANGY LOW HEAD DAM

Question Submitted: 7/21/2010 8:45:06 AM

When will the EBS file be available for downloading? Thank you.

The EBS is now available for download