

Ohio Department of Transportation

Prebid Questions

Project No. 108041

Sale Date - 6/3/2010

Question Submitted: 5/25/2010

Question Number: 1

Would the department please make both the full plan set and noise barrier shop drawings from the original project available online?

Question Submitted: 6/1/2010

Question Number: 2

What is the spacing of the ss tabs of post covers? Explain the fiber cement backing? How are the ss tabs to be cast in post covers? If a 8' panel is used, the post cover will weigh approximately 196 lbs. This will not be easily handled by hand.

A1. The tabs run the full length of the post covers as shown on sheet 18/19. A2. The fiber cement backing is to protect the existing posts and provide a smooth, consistent surface for the post covers. A3. That is a manufacturing issue. A4. This isn't a question, but the post cover joints must match the panel joints.

Question Submitted: 6/1/2010

Question Number: 3

After talking with the suppliers, it appears that the completion date of 10/31/2010 is unrealistic. There are over 5000 pieces to cast for the post caps alone. They physically can not be produced before the completion date. Will the Department revise the completion date to 08/01/11?

We feel the completion date is realistic. Bid as per plan.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.