

Ohio Department of Transportation

Prebid Questions

Project No. 100379

Sale Date - 6/3/2010

Question Submitted: 5/27/2010

Question Number: 1

Are there any soil borings for this project? And if so, can I get a hold of a copy?

Those 4 soil sheets are included with the plans online.

Question Submitted: 5/27/2010

Question Number: 2

Ref 142 sheet 151 Mark W602 is missing the weight which would add 1079 lbs to the pay item. Also Mark S607 is missing quantity and lengths. Please verify.

Question Submitted: 6/1/2010

Question Number: 3

As indicated in the "POTENTIAL SEQUENCE OF CONSTRUCTION" note on page 12/151 Part 2 and 3 for the West 76th pedestrian tunnel is to be completed between 9/7/10 and 11/15/10. There is a large amount of work in a confined area associated with completing part 2 and 3 in this 69 day period. Please consider extending or eliminating the interim completion.

The paragraph above the "POTENTIAL SEQUENCE OF CONSTRUCTION" note on page 12/151 restricts the CLOSURE of the pedestrian tunnel itself for long term until after 9/6/10. The contractor is still able to work in the area using short term closures for the pedestrian tunnel. The interim completion date remains.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.