

Ohio Department of Transportation

Prebid Questions

Project No. 040446

Sale Date - 7/28/2004

Question Submitted: 7/21/2004

Question Number: 1

Note of Plan Sheet 3/7, left column states that surface finish requirements shall be as per 511.19 and 511.20 in lieu of SS848. Will this note be construed to require the contractor to place the curing compound required in 511.20?

The curing is to be performed as per SS 848...which is water cured. We are only addressing the surface finish (texturing) per 511.19 and 511.20. There is no cross reference of a curing specification in 511.19 or 511.20. Curing is not a surface finish.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.