

Ohio Department of Transportation

Prebid Questions

Project No. 060314

Sale Date - 7/12/2006

Question Submitted: 6/29/2006

Question Number: 1

This project has 17 bridges to receive new asphalt resurfacing with pavement reinforcing fabric. The plans and the proposal fail to identify the material (brand names) to use for the pavement reinforcing fabric. Please specify.

Question Submitted: 7/6/2006

Question Number: 2

WHAT MATERIAL IS SUPPOSED TO BE USED AS A MASTIC FOR THE PAVEMENT REINFORCING FABRIC? DID YOU WANT PG64-22 LIKE A NORMAL PETROMAT INSTALLATION OR D-3405 SEALANT(TYPE 3 WATERPROOFING MEMBRANE MASTIC)?

The general note for the item Special Pavement Reinforcing Fabric states: "The asphalt sealant shall be PG 64-22 meeting the requirements of 702.01"

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.