

Ohio Department of Transportation

Prebid Questions

Project No. 070159

Sale Date - 3/16/2007

Question Submitted: 3/12/2007

Question Number: 1

Please refer to the note on page 10 of the plans concerning Item 517 - Bridge Railing Rebuilt, As per Plan (Proposal Line Item #0005). It states that the slot on the existing post may need to be lengthened to obtain correct height or new posts may be needed. Our question is, how far would you allow the slot to be lengthened, or would you allow the tubular railing block to extend above the top of the post? If so, how far?

The slots in the posts can be lengthened so that the minimum distance from the edge of the slot to the end of the post is 9/16". The tubes may extend above the post, however, do not lengthen the bolt holes in the tubes.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.