

# Ohio Department of Transportation Prebid Questions

Project No. 060041

Sale Date - 1/27/2006

---

Question Submitted:

Question Number: 1

1) Do you know if any of the existing paint contains lead? 2) Plan sheet 3/8 Limitations of Operations note #3. work shall be completed by Sept 15, 2005?

**A1) IT IS UNKNOWN WHETHER THE EXISTING PAINT CONTAINS LEAD. LEAD CONTENT SHALL BE DETERMINED DURING CONSTRUCTION AS PER ITEM 514. A2) WORK SHALL BE COMPLETED BY SEPTEMBER 15, 2006. The completion date is correct in the Proposal, and per CMS 105.**

Question Submitted: 1/6/2006

Question Number: 2

With reference to ITEM 514 Painting of Structural Steel, 514.13 Surface Preparation. B. Grinding Flange Edges (QCP #2). Before abrasive blasting, round all exposed bottom flange edges of all beams to a radius of 1/8  $\approx$  1/16 inch (3  $\approx$  1.5 mm).....ö on

Question Submitted: 12/27/2005

Question Number: 3

SUPPLEMENTAL SPECIFICATION 885, PAINTING OF STRUCTURAL STEEL WITH WARRANTY, Section 885.05

Does this section mean that the contractor must provide "OSHA approved, vehicle-mounted inspection equipment capable of accessing all areas of the structure" for

**In response to the prebid question for Project: 060041, Construction offers the following: "This inspection" is referring to all annual and final reviews in connection with "The Engineer will inspect the bridge thoroughly for the structural steel pain**

Question Submitted: 12/28/2005

Question Number: 4

1: Bridges CUY-422-1468L&R and CUY-422-1597L&R carry Rte 422 over Mills Road and Cannon Road respectively. Each of these roads are single lanes in two directions. Can portable traffic lights be used at each site to direct traffic under the bridges during

---

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.