

Ohio Department of Transportation

Prebid Questions

Project No. 100390

Sale Date - 6/10/2010

Question Submitted: 5/28/2010

Question Number: 1

There is no pay item for 606 Guardrail Nested Type 5 with Tubular Backup specified on page 16. Please clarify.

Bid line item 58 is 50 feet of Guardrail, Nested Type 5 with Tubular Backup.

Question Submitted: 5/28/2010

Question Number: 2

We are requesting the State to review and consider changing the 8/10/10 completion for this project. The project has a 6/3/10 bid date. Allowing for the award, contract, purchase and fabrication of the box culverts, the 8/10/10 completion is tight for the construction of the two structures. Please consider extending the completion date to 9/30/10.

We will change the completion date to 9/30/10 by addendum.

Question Submitted: 6/1/2010

Question Number: 3

In the Culvert General Notes on page 14/29, the Culvert Backfill note indicates the culvert shall be backfilled using Low Strength Mortar (LSM) Backfill. Please confirm this note is correct? If this note is correct, what are the limits for the LSM backfill? In the case of structure DAR-705-9.77, the contractor will be replacing a three span bridge with a box culvert, the void between the existing structure and the proposed structure will be substantial.

We will clarify this in addendum 3.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.