

# Ohio Department of Transportation

## Prebid Questions

Project No. 080479

Sale Date - 7/23/2008

Question Submitted: 7/19/2008

Question Number: 1

What type of paint are you requesting for Line items 2 through 8? We only see item 642. Is it Item 642 Type I waterbase or Item 642 Type II oilbase? Also, for line 20 can thermo plastic be used in place of the Epoxy since it is only 300 FT? Thanks

**A1: When none is specified it is the contractors choice except that the CMS calls for Alkyd based paint for below 50 deg. F. A2: We really needed epoxy. This is concrete pavement.**

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.