

Ohio Department of Transportation

Prebid Questions

Project No. 080629

Sale Date - 11/19/2008

Question Submitted: 9/25/2008

Question Number: 1

Bid reference 137 1 Ea Pull Box, 725.08, 36". After review of the plan sheets and the general notes I have been unable to locate a detail for this pull box. Will the engineer provide a detail so the pull box can be fabricated.

The pull box specified in the plans would have a 36" inside diameter and is round and shall meet the requirements of C&MS 625. We do not feel more detail is needed.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.