

Ohio Department of Transportation

Prebid Questions

Project No. 080546

Sale Date - 9/24/2008

Question Submitted: 9/15/2008

Question Number: 1

Question #1 On sheet 10 and 11, is the grounding and bonding spec required to be performed on the existing system? or only on the new work being installed? Questions #2 would it be acceptable to install a 30" or 36" dug round foundation and formed square on top in lieu of the type 1 foundations specified in the various plan sheets for the UPS foundations? this would be similar to the foundations being used in district 12 for the same purpose.

A1) New work only. A1) Bid and perform work as specified in the bidding documents.

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.