

Ohio Department of Transportation

Prebid Questions

Project No. 060232

Sale Date - 5/26/2006

Question Submitted: 5/19/2006

Question Number: 1

Ref 81 Epoxy - Sheet 33A/49 - For the deck sidewalk there are Marks S401,S402,S403 & S404 shown on sheet 42/49 coming out of the precast beams. Shouldn't these bars be supplied w/the precast beam, not ref 81?

These bars in question amount to 2288 pounds of epoxy coated reinforcing steel for the exposed area of deck under the sidewalk. The contractor will coordinate the placement as indicated in the plan.

Question Submitted: 5/3/2006

Question Number: 2

Good Morning!

In regards to Project Number 060232 on the May 26th letting, line item 0057 is specified for use of 5 ea. work zone impact attenuator Quadguard CZ, QZ2403Y. We are the distributor for Trinity Industries TRACC family of crash cushions that was recently approved in Ohio for permanent and work zone sites. Trinity's SHORTRACC is an equivalent to the Quadguard CZ, QZ2403Y. Would it be possible to let contractors know that this would also be an approved unit for this job?

Thanks,
Leslie

Trinity's TRACC is a newly approved Type 2-98 impact attenuator, so we consider it equal to the QuadGuard and also the TAU. All three products have a wide variety of models, each based on design speed of the facility and the width of the hazard. (See Sample Plan Note R124). The TRACC has a model equivalent to the QuadGuard's 2403

All prospective bidders, subcontractors, suppliers, materialmen and all others who have an interest in these prebid questions and answers are advised that these items are being provided for informational purposes only and are not part of the bidding documents. If a question warrants a clarification, the Department will issue an addenda addressing the request for clarification to all plan holders. If the Department believes that the bidding documents adequately address the request, the contractor will be advised accordingly.